

Certificate of Conformity

Certificate Number: CN-PV-220188

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shenzhen Hopewind Technology Co., Ltd. A1 Area of Building 6, Jinhaoyuan, No.1 of Yanshan Avenue, Yanchuan Community, Songgang Sub-district, Baoan District, Shenzhen, Guangdong Province China
Product:	Grid-connected PV inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	hopeSun xxKTL-L (xx= 10, 12, 15, 17, 24 and 30) hopeSun xxKTL (xx= 5, 6, 8, 10, 12, 15, 17, 20, 22, 25, 30 and 33)
Brand Name<s>:	Hopewind
Product Complies with:	IEC 62109-1:2010, IEC 62109-2:2011 EN 62109-1:2010, EN 62109-2:2011
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	220201177SHA-001 220201177SHA-002

Additional information in Appendix.

Signature



Certification Manager: Qiao Qiao
Date: 02 September 2022



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.