

# Unit Certificate (Einheitenzertifikat)

Certificate No. (Zertifikats-Nr.): CN-PV-230625

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Anhand der durchgeführten Tests wurde festgestellt, dass die Probe (n) des nachstehenden Produkts zum Zeitpunkt der Durchführung der Tests den Anforderungen der angegebenen Spezifikation (n) / Norm (en) entsprachen. Dies bedeutet nicht, dass Intertek die Herstellung (en) überwacht oder kontrolliert hat. Der Hersteller stellt sicher, dass der Herstellungsprozess die Übereinstimmung der Produktionseinheiten mit den in diesem Zertifikat genannten geprüften Produkten sicherstellt.

**Applicant:**  
(Antragsteller)

Shenzhen Hopewind Technology Co., Ltd.  
Room 101, Building B, No.94, Guangtian Road, Yanchuan Community,  
Yanluo Street, Bao'an District, Shenzhen, China  
GRID-CONNECTED PV INVERTER

**Product:**  
(Produkt)

**Model:**  
(Modell)

**Max. active power P<sub>Emax</sub>:**  
(max. Wirkleistung P<sub>Emax</sub>)

**Max. apparent power S<sub>Emax</sub>:**  
(max. Scheinleistung S<sub>Emax</sub>)

**Rated voltage:**

(Bemessungsspannung)

**Rated current (AC) I<sub>r</sub>:**

(Bemessungsstrom (AC) I<sub>r</sub>)

**Initial short-circuit AC current I<sub>k</sub>:**

(Anfangs-Kurzschlusswechselstrom I<sub>k</sub>)

**Tested according to:**

(Geprüft nach)

HSNV36K-G01, HSNV40K-G01, HSNV50K-G01,  
HSNV60K-G01, HSNV70K-G01, HSNV75K-G01  
36.46kW ; 40.47kW ; 50.40W; 60.63kW; 70.48kW; 75.62kW

40.35kVA ; 44.86kVA ; 56.08kVA; 67.30kVA; 78.33kVA; 83.91kVA

400Vac

52.0A ; 57.7A ; 72.2A; 86.6A; 101.0A; 108.3A

57.2A ; 64A ; 80A; 86.6A; 95A; 111A; 119A

VDE-AR-N 4105: 2018-11 "Generators connected to the low-voltage distribution network"

Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network

DIN VDE V 0124-100 (VDE V 0124-100):2020-06 "Network integration of power generation systems – Low voltage"

Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network

230830084GZU-002, 08 November 2023

**Test Report No.:**

(Prüfbericht-Nr.)

**Certificate Issuing Office:**

(Stelle des ausgestellten Zertifikats)

Intertek Testing Services Ltd. Shanghai

West Area, 2nd Floor, No. 707, Zhangyang Road


China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China

Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012

The above designated power generation unit meets the requirements of VDE-AR-N 4105: 2018.

Die oben bezeichnete Erzeugungseinheit erfüllt die Anforderungen der VDE-AR-N 4105: 2018.

See Appendix page for detailed technical information (Detaillierte technische Informationen siehe Anhang).



**Signature (Unterschrift)**

**Certification Manager: Grady Ye**

**Date (Datum): 16 November 2023**



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Dieses Zertifikat ist ausschließlich für den Kunden von Intertek bestimmt und wird gemäß der Vereinbarung zwischen Intertek und seinem Kunden zur Verfügung gestellt. Die Verantwortung und Haftung von Intertek ist auf die Vertragsbedingungen beschränkt. Intertek übernimmt keine Haftung gegenüber anderen Parteien als dem Kunden gemäß der Vereinbarung für Verluste, Kosten oder Schäden, die durch die Verwendung dieses Zertifikats entstehen. Nur der Kunde ist berechtigt, das Kopieren oder Verteilen dieses Zertifikats zuzulassen. Jede Verwendung des Intertek-Namens oder einer seiner Marken für den Verkauf oder die Werbung für das getestete Material, Produkt oder die getestete Dienstleistung muss zuerst von Intertek schriftlich genehmigt werden.